



- (A) Mount tip with a 4° up angle or more
- (B) Tip needs to be in contact with area to be measured

Two Conductor Shielded Cable #22 AWG



5580 Enterprise Pkwy. Fort Myers, FL 33905 USA
 Phone: 239-694-0089 • www.mcsccontrols.com
support@mcsccontrols.com