



SOFTWARE RELEASE NOTES

MCS-CONNECT
Version 8.10N
08/17/2011

Updates from previous versions:

New Features:

1. Added pumps and boilers tab to the status panel named "Boiler". This will contain the Pump capacity grid, pump circuit grid, boiler capacity grid, and boiler circuit grid. This panel will only be shown if boiler logic is enabled.

Pump Capacity State	Time	Step Delay	Rate of Change	Wanted/Actual /Available	Wanted VFD%	VFD% Delay
PUMPS STOPPED	00:02:08	20	0.0	0/0/1	0.0	0
Pumps State	Time	Lead?				
1) PUMP OFF	00:04:16	Yes				
2) PUMP OFF	00:04:16					
Pump Capacity State	Time	Step Delay	Rate of Change	Wanted/Actual /Available		
BOILER STOPPED	00:02:08	20	0.0	0/0/4		
Boilers State	Time	Lead?				
1) STP swOFF	00:04:16	Yes				
2) STP swOFF	00:04:16					
3) STP swOFF	00:04:16					
4) STP OFF	00:04:14					

Status Alarms SetPoints Reset/Clear Schedule Service **Boiler**

2. Added Wanted FLA% functionality to REFR configs (same logic as HVAC).

Bug Fixes:

1. Fixed bug in REFR software that was updating the timer incorrectly when going into the Anticycle state.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.