



SOFTWARE RELEASE NOTES

MCS-CONNECT
Version 9.01
10/31/2011

Updates from previous versions:

New Features:

1. Added 3 new columns to the Superheat Grid: Subcooling, Liquid Temp, Sat. Liquid Temp. All 3 are dynamically displayed if config is set up for them. Moved "Ref Type" column to the Capacity Control Grid.
2. Added authorization level: Administrator. This is the highest level and allows the user to make all changes. The Clear Points and Clear Alarms functions will now be available only to Administrator level. Factory level will no longer allow Clear Points and Clear Alarms functions. All other functions can be performed with factory level.
3. Added support for refrigerant type R-423A.
4. HVAC SOFTWARE ONLY: Added "Starting Comp %" and "Time" fields in the RO Grid popup if Compressor Speed AO is used and Hot Gas Bypass is not a modulating type. Valid ranges for each are 0-100 for Compressor % and 0-240 for Time.

Bug Fixes:

1. Changed 4 alarms to be excluded from the extended lockout history points alarms: "RO TO AUTO", "AO TO AUTO", "SI TO AUTO", "RO TO MANOFF".

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.