



BMS 485 Address (Bacnet MSTP)
See Documentation for Details.

Addressing Values	
A0	1
A1	2
A2	4
A3	8
A4	16
A5	32
A6	64
A7	128

The values of the switches in the on position are added together to determine the module's address.

MCS-BMS-Gateway	MCS-BMS-Gateway DIP Switches			
Profile - MCS-BMS-Gateway	S0	S1	S2	S3
Bacnet MS/TP	On	Off	Off	Off
Johnson N2	Off	On	Off	Off
Modbus IP to RTU	On	On	Off	Off

Baud	B0	B1	B2	B3
Auto	Off	Off	Off	Off
9600	On	On	On	Off
19200	Off	Off	Off	On
38400	On	On	Off	On
76800	On	Off	On	On
115200	Off	On	On	On