



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.00E 06/17/2013

Updates from previous versions:

New Features:

1. In ALL config types V14 on the Setup screen adding the panel that is in V11 config files that is for selecting the Type of I/O Boards. Along with this change adding in the source code that is needed when the type of I/O board is tested for grid sizes and print functions.
2. In ALL config types V14 on the Setup screen under the Generate Alarm for Network Time Synchronization panel adding a panel called Generate Alarm When Configuration Updated that will have a YES/NO condition.
3. In ALL config types V14 on the Setup screen on the Ethernet Communication panel adding a panel called BACnet MV Values Start At: that will have two radio buttons on it: Zero and One. This option will change the starting point to either 0 or 1 of the Unit States and Alarm States on the BMS Points screen.
4. In ALL config types V14 on the Setup screen below the Max Lockout Resets Per Day panel and drop down adding a panel called Lockout Reset that will join with an SI drop down list to select the sensor to point to.
5. In MicroMag config types RTU adding two new SI names. Adding and changing Setpoint names.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.