



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.00F 06/20/2013

Updates from previous versions:

Bug Fixes:

1. In HVAC & RTU config types V11 and V14 on the MAG INFO screen when an option shows or hides drop down lists that allow points to be selected the points are not cleared when the option selected is Not Used or None. Resolution: When an option to hide the points is selected then set all of the hidden points memory locations back to Not Used or 0. The following panels are being affected with this change: RTU-Ventilation Info>Building PSI Control-removing the popup and clearing all points on Not Used and Reverse, Exhaust Damper, Outside Air Damper, Supply Fan..Condenser Info>Dehumidification and Humidification HVAC Evaporator Info>Subcooler Valve Control, Economizer Control>Condenser Info Reset All drop downs that are hidden when the condenser type is changed to No Condenser.
2. In RTU config types V11 and V14 on the MAG RTU panel under the general section rearranging and renaming some of the inputs on the Control Mode On: panel. Removing the Control Mode On: text and replacing it with Fan Only Mode:
3. In ALL config types V14 adding in BMS Points for 32 more SIs, 25 more Setpoints, and 8 new AOs to the BMS Points screen and the CSV files when created.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.