



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.00I 07/08/2013

Updates from previous versions:

New Features:

1. In LWC config types V14 versions on the MAG LWC screen adding three new columns called: Pump Alarm Starting #, Cooling Alarm Starting #, and Heating Alarm Starting # each with a range of 1-30. These will be saved in lwcV14eeprom bytes #61(Pump), #75(Cooling), and #88(Heating).
2. In MicroMag config types added new SI names to both RTU and CHL SI name arrays.

Bug Fixes:

1. In ALL config types V11 and V14 versions on the Setup screen on the Daylight Savings Time panel the daylight savings time hour field cannot be a 0. Resolution: Remove the 0 selection from the drop down list.
2. In ALL config types V14 versions on the MAG INFO screen under the General and Compressor sections when the Compressor Type is a TurboCor type then the fields on the General Info panel for # of Circuits and # of Steps should be limited to a range of 1-6. Resolution: When the form loads or when the compressor type is changed if the type is TurboCor then hide the original drop down lists for # of Circuits and # of Steps and show two new drop down lists that have a range of 1-6 only.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.