



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.00Q 10/01/2013

Updates from previous versions:

New Features:

1. In RTU config types V14 on the BMS Points screen under the unit control info section adding new state charts at the bottom of the page and adding new states to Building Mode, RTU State, and Heat State.
2. In ALL config types V14 on the main screen adding a button called User Logic Points to the right of the BMS Points button that when clicked will display the user logic state grids.
3. In MicroMag config types V12 finishing the BMS Points screen and enabling the BMS Points button on the main screen.

Bug Fixes:

1. In RTU config types V11 and V14 on the MAG RTU screen under the Heating Info section on the Primary/Auxiliary panels when the Primary heating type is MOD SCR then the Auxiliary panel will now be hidden and the four drop down lists: Starting RO, # of Stages, Starting Stage, and # of Stage Faults on the Auxiliary panel will be grouped together with the MOD SCR AO and MOD SCR Fault drop down lists on the Primary panel.
2. In MicroMag config types V12 adding 5 and modifying 5 SI names for RTU types.
3. In MicroMag config types V12 on the MICRO MAG screen for an RTU type under the General section on the Supervisory Controls panel when the Supervisor Mode is set to Forced Mode changing the caption of the Cool/Heat Demand SI box to Cool Enable SI and changing the caption of the Demand/Enable SI to Dehumid Enable SI.
4. In PAO config types V11 and V14 on the Circuit Base screen on the Condenser grid at the bottom of the screen when selecting a value for any of the columns or rows the value is saved correctly but then when a value is selected on a different column or row and then clicked off of that row anywhere in the grid the first value selected is set back to default. Resolution: Added a test for PAO config type so the correct memory location is being tested for when testing for the Condenser Type.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.