



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.00V 11/04/2013

Updates from previous versions:

Bug Fixes:

1. In ALL config types V11 and V14 on the setpoint info screen under the High Zone, Low Zone, Night Setback, MIN VFD Opening, MAX VFD Opening, and MAX VFD Adjustment columns when the Type of Setpoint column is not set to a Lockout or Alarm type then these six columns are used depending on the setpoint type. The range allowed in these six columns is 0 to 32767 relative to the decimal places allowed by the Select Value column when the range should be -32768 to 32767. Resolution: change the allowed range for these six fields to -32768 to 32767 depending on decimal place in the type.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.