



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.01C 02/20/2014

Updates from previous versions:

New Features:

1. In HVAC config types V14 on the BMS Points screen under the Compressor Points section adding a new state to the MCS Circuit State Chart.

Bug Fixes:

1. In ALL MicroMag config types V12 on the Micro Mag Info screen under the Ventilation Info screen moving the Co2 Sensor panel to the Outdoor Air Damper panel and making it Visible or Invisible depending on the Control Method selected. Also, moving Building PSI Control over to the right next to the Energy Recovery Wheel panel. Also, on the Energy Recovery Wheel panel changing the captions from Temp for Frost Point Calc and Humd for Frost Point Calc to Temp-Frost Stpt Calculation and Humid-Frost Stpt Calculation.
2. In RTU config types V14 on the MAG RTU screen under the General and Ventilation sections moving the Econ Control O/S and Econ Control Return panels from the General screen to the Ventilation screen on the Outside Air Damper panel. Also changing the caption of the Outside Air Damper Supply Air to Outside Air CFM.
3. In ALL MicroMag config types on the setpoint info screen under the value column when printing the setpoint grid info the value column is dividing the value by 1, 10, or 100 depending on the number of decimal places set in the Select Value column. If the setpoint type is set to a delay type then config was not converting the decimal places which was not consistent with the MicroMag software. Resolution: Comment out the test for a Delay type of setpoint in the update routine of the setpoint grid.
4. In ALL config types V11 and V14 that support BMS when the CREATE MCS-BMS-GATEWAY CSV FILES button is clicked the Lontalk file that is created is not printing setpoints 1, 21, or 163 under the Input Values section on the server side of the csv file. Resolution: Add the test for the missing setpoints under the input section so those setpoints are now displayed.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2014. Copying or distributing this document is prohibited unless expressly approved by MCS.