



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 14.01F 04/11/2014

Updates from previous versions:

Bug Fixes:

1. In ALL config types V14 that support the Circuit Base screen on the first grid which is the compressor grid when the Tandem EXV Circuit # column on the bottom grid which is the condenser grid is set to work in tandem with other circuits the tandem circuit rows are not being colored light blue on the top grid. Resolution: In the form load procedure the Cell Style property is not set to light blue for the compressor grid. Adding source code to set the Cell Style property to light blue.
2. In ALL config types V11 and V14 that support BMS Points when the CREATE MCS-BMS-GATEWAY CSV FILES button is clicked and the BACnet file is created on the Server side of the file under the Writable Values section under the Object ID column if a new writable SI is added to the cfg file and a new .csv file is created and downloaded to the MCS-BMS-GATEWAY then the Object ID values are shifted by one. Resolution: Move the writable AV counter variable incrementation out of the test for a writable setpoint into the loop itself so for each setpoint the counter is incremented.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2014. Copying or distributing this document is prohibited unless expressly approved by MCS.