



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 17.00D 11/04/2014

Updates from previous versions:

New Features:

1. In CPM config types V17 on the MAG CPM screen on the Control Options panel adding three new Yes/No conditional panels called: Chilled Water Has Bypass Valve, Condenser Water Has Bypass Valve, and Cooling Tower Has Bypass Valve.
2. In ALL MicroMag config types V12 on the MICRO MAG screen under the RTU group under the General Info section on the Unit Control panel adding a new SI drop down combo box called Thermostat Run/Stop.
3. In CPM config types V17 on the MAG CPM screen under the Chiller Info section adding a new column to the Chiller Setup grid called Condenser Pump Group. This column will have a number drop down list 1-5 and will also have a Not Used selection.
4. In CPM config types V17 on the MAG CPM screen under the Pump Info section on the Pump Group grid adding a new column called Pump Group Type. There will be two selections for the column called Chilled Water and Condenser Water.
5. In CPM config types V17 on the MAG CPM screen under the Pump Info section on the Pump Group grid adding a new column called Max Pumps Per Chiller. This will be a numerical value column that will have a range of 1-10. If the value is less than 1 or greater than ten then the default value will be 10.

Bug Fixes:

1. In ALL config types when the file save button on the menu bar is clicked and the File Save Dialog is opened the file folder path is incorrect if there are two or more instances of MCS-Config open. Resolution: Revert a previous change to correct this one as this one has higher priority over the other change and instead placing the current file name in the convert function from V14 to V17 to help the user choose the correct file name for the newly converted cfg file.
2. In ALL config types V17 on the SI Info screen when the Display Type selected is User Defined or Percent the SI wizard popup dimensions are incorrect. Resolution: Change the width and height properties for the V17 version to match that of previous versions.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2014. Copying or distributing this document is prohibited unless expressly approved by MCS.