



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 17.00K 01/12/2015

Updates from previous versions:

New Features:

1. In ALL MicroMag config types V12 on the SI info screen under the Display Type column alphabetizing the drop down list.
2. In ALL config types that support BMS Points on the BMS Points screen under the Alarms section on the Fixed Alarms grid adding 17 new alarms to the end of the list.

Bug Fixes:

1. In HVAC config types V17 on the MAG HVAC screen under the Compressor Info section there are two panels that are showing and they should not be. They are only supposed to show in CENT config types. Resolution: Set the panel's visible property to false if not CENT.
2. In HVAC config types V17 on the MAG HVAC screen under the Compressor Info section on the Compressor Economizer Control (3rd LLS) panel the options are saving to Setpoint #99 opposite of how they need to be saved. Resolution: Changing the value that gets set to Setpoint #99 when the options are clicked.
3. In ALL config types V17 on the AO info screen under the Control Type column when the type is set to Modbus Write and the AO Modbus Write wizard is set to the values expected when the wizard is closed the Modbus Display Type column is not set to the Display Type that is set in the wizard. Resolution: In the update function for the grid add the Modbus Write type to the test that sets the Modbus Display Type column.
4. In CPM config types V17 on the MAG CPM screen under the Chiller Info section on the Chiller Setup grid under the Cooling Tower Group column there is not an option in the drop down list for Not Used. Resolution: Add Not Used to the drop down list and add the source code needed to handle the new option.
5. In ALL config types V17 on the AO info screen under the Control Type column the Modbus Write control type does not have a print option in the print wizard dialog box. Resolution: Adding the source code and check box to give the user the ability to print the Modbus Write AO(s) when the print dialog is open.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2015. Copying or distributing this document is prohibited unless expressly approved by MCS.