



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 17.00R 04/13/2015

Updates from previous versions:

New Features:

1. In ALL RTU MicroMag cfg types V12 on the MICRO MAG info screen adding a new panel called Target Reset Sensors that will hold three new SI drop down lists called Cooling Target Reset, Heating Target Reset, and Reheat Target Reset.
2. In ACU cfg types V17 on the MAG ACU info screen on the Evaporator Fan Information panel adding an SI drop down called Evap Fan Amps.
3. In HVAC cfg types V17 on the Circuit Base screen on the grid at the bottom adding a new column at the end called Subcooler Refrigerant Level.
4. In ALL RTU MicroMag cfg types V12 on the Circuit Base screen on the top grid under the Compressor Type column adding a new type to the drop down list called Hot Gas with Unloaders.
5. In ALL MicroMag cfg types V12 on the SI Info screen under the Name column adding in 4 new names to the SI name array: Oil PSI 1-4.

Bug Fixes:

1. In ALL config types V17 on the AO info screen under the Control Type column when a Linear Control is selected and the User Logic wizard popup appears, if a Setpoint is chosen for the Type under the Minimum Value section then the app crashes with a Run-time error #6 Overflow. Resolution: On the close-up event of the drop down list the clock type drop down had an incorrect index value.
2. In ALL config types V14 and V17 that support BMS, on the BMS Points screen when the CREATE MCS-BMS-GATEWAY CSV FILES button is clicked and the BACnet file is created the Client side values do not match up to the Server side values. Resolution: On the server side of the create BACnet csv file function there were some lines of source code that were V14 instead of V17 cfg version.
3. In ALL cfg types V14 and V17 the support for the old RO8-SI16-AO4 boards was removed and now needs to be added back. Resolution: Add the source code needed to handle the old style boards.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2015. Copying or distributing this document is prohibited unless expressly approved by MCS.