



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 17.00Y 10/16/2015

Updates from previous versions:

New Features:

1. In uMag MICROMAG config types V12-RTU adding a new relay name to the RO Names memory location. New name is 3 Way Valve.
2. In uMag MICROMAG config types V12-RTU & CHILLER adding a new sensor names to the SI Names memory location. In RTU uMag type the new names will start at 159 and end at 192 and for CHILLER uMag type the new names will start at 86 and end at 117.
3. In ALL MICROMAG config types V12-RTU adding a new relay name to the RO Names memory location and a new analog name to the AO Names memory location. New RO name is CHW Valve and will be stored as #96 for AAON and uMag and #99 for SKM. New AO name is CHW Valve and will be stored as #67 for AAON, uMag, and SKM.
4. In ALL config types V17 on the SI info screen under the Display Type column adding 4 new sensor types to the end of the list: RKNG F1(164), RKNG F2(165), RKNG F3(166), RKNG F4(167).
5. In uMag MICROMAG config types V12-RTU adding three new panels with options to the Cooling Info panel, 1 on the Preliminary Cooling panel: Pre-Cool and Condenser CHW Line Sharing ON/OFF option(byte #108 rtueeprom - ON = xxxx xxx0 OFF = xxxx xxx1, AND 2 on the Dehumidification panel: Force Compressors on When in Dehumidification? YES/NO option(YES = xxxx xx0x NO = xxxx xx1x) AND Reheat Control on Supply Temp? YES/NO option(YES = Reheat Control SI Drop Down-Not Used NO = Reheat Control SI Drop Down-SI Index)

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2015. Copying or distributing this document is prohibited unless expressly approved by MCS.

Bug Fixes:

1. In ALL config types V17 on the SI Info screen under the Display Type column if the type that is selected is set to DIGITAL then the Display Text column is not allowing a change to be made. Resolution: Add the DIGITAL type back to the drop down click test.
2. In ALL config types V17 on the print popup, if the Relay Output Detailed Info is selected the RO info is not printing. Resolution: Test for V17 cfg was not put in place after the conversion, adding V17 to test.
3. In ALL config types V14 to V17 conversion, the RO Info grid Comments column is being filled with numerical values which causes all 80 ROs to be Commented. Resolution: Adding a test to check for this error and clear the memory locations if the error occurs at the end of the file.
4. In ALL config types V17 when the file is saved concatenating the text "_Rev_" and the Revision # value that is on the System screen to the file name saved.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2015. Copying or distributing this document is prohibited unless expressly approved by MCS.