

MCS Release Note

Product Type: MCS-Config Software Revision: 19.01.15

Release Date: July 23, 2025

Release 19.01.15 - Wednesday, July 23, 2025 Log:

Overall Summary:

- Added more features for the upcoming PMGR software type involving Control SI's and additional features. Support for setting Number of Rapid Starts to Magnum V17. Removed RS485 BACnet MSTP port limitation. Fixes to visual bugs.

Bug Fixes:

- Fixed a visual bug that was cutting off "Heat Recovery" text in the General Info screen in HVAC V19 configs.
- Fixed a visual bug that was opening the V17 BMS form after generating MCS-BMS Gateway CSV files

Major Bug Fixes:

- Bug fix for Runtime error on EXV Control screen. We were pointing to the wrong (REFR) circuit EEPROM.

New Features and Enhancements:

- Added a dropdown selection box for setting three different control SI's to the General Screen (HVAC V19 only): Force Heat Recovery Mode, Force Cooling Mode, and Condenser Flow.
- Added a new column to the Circuit Base grid for setting the Number of Rapid Starts to V17.
- Allowing users to set both RS485 ports as BACnet MSTP in V19 setup screen.

V19 PMGR Updates:

- Added support for setting up to 15 network addresses for V19 PMGR software device info screen.
- Added new column to Device Info Setup grid for setting "Hot Water Pump Group" for V19 PMGR software.
- Added two new columns to Pump Info Pumps grid for setting "Bypass Valve Proof SI" and "Bypass Valve Relay" for V19 PMGR software.

Patches:

- Disabled MCS-BMS Gateway CSV Generator button until it is ready with the new V19 BACnet updates.