



SOFTWARE RELEASE NOTES

MCS-CONFIG Version 8.00K 03/22/2011

Updates from previous versions:

New Features:

1. New Pump and Boiler support logic has been added to MCS-Config. A new panel has been added to the MAG V8 screen to configure this option. Requires HVAC software version 8.05-G or newer.

Magnum HVAC V8 Information Screen

Information Panel Selector

☐ General Info ☐ Compressor Info ☐ Evaporator Info ☐ Condensor Info ☐ Lockout Info ☒ **Boiler Info**

Boiler Information

Enable Boiler Logic? ☒ Yes ☐ No	Pumps Pump Control ☒ Always On ☐ Cycled On Temp # of Pumps: 1 Pump In PSI: Not Used Pump Out PSI: Not Used Pump VFD: Not Used Pump VFD Fault: Not Used Starting Pump R0: Not Used Starting Pump Proof: Not Used Starting Pump Fault: Not Used Max Pumps Allowed: 0	Boiler # of Boilers: 0 Starting Boiler R0: Not Used Max Boilers Allowed: 0 Starting Boiler Proof: Not Used Starting Boiler Fault: Not Used
General Run/Stop Switch: Not Used Alarm Relay: Not Used Control On: ☐ Water In ☒ Water Out Water In: Not Used Water Out: Not Used		

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.