



SOFTWARE RELEASE NOTES

MCS-CONNECT
Version 17.08.08
11/10/2015

Updates from previous versions:

New Features:

1. Added a label to the Alarm lockout info popup to display basic Alarm info in each popup.
2. New Capacity Control state added for V17 code. #38, "UNIT IS OFF/TEMP"

Bug Fixes:

1. Changed the alarm alert files saved to the same files as the Diagnostic Save. Also changed both saves to create a sub directory named after the HW Serial #.
2. Fixed the issue with the multiple selectors in the Options Setup just clearing without setting the reverse option to true by adding button groups.
3. The alarms grid is displaying incorrectly when the "Show lockout alarms only" option is selected. Changed the functionality to match the way the other grids hide spare rows. The non lockout alarm rows height will now be set to 1 when this option is selected.
4. Fixed a bug that was throwing an exception when entering a FACTORY_STARTUP_LEVEL or RUN_HOUR_LOCKOUT_LEVEL auth code.
5. V17 RTU control on field showing cooling Control on value. Added a check to display the correct Control on SI when in dehumid state.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2015. Copying or distributing this document is prohibited unless expressly approved by MCS.