



## SOFTWARE RELEASE NOTES

---

# MCS-MAGNUM Version 14.00D 06/08/2013

### Updates from previous versions:

#### New Features:

1. RTU-Added 100% Outside Air Makeup based on CO2 demand. This changes how the supply fan is controlled. Purpose is to run supply fan at a minimum speed while maintaining an acceptable CO2 level and maintaining a minimum CFM based upon cooling or heating mode.

#### Bug Fixes:

1. HVAC and RTU-Compressor running test uses compressor speed AO index. Resolution: Must use the ao from the circuit as this index will contain ao from circuit in the same suction group.

Any questions regarding this release, contact:  
[support@mcscontrols.com](mailto:support@mcscontrols.com)

---

**Micro Control Systems, Inc.** 5580 Enterprise Parkway Fort Myers, Florida 33905  
(239)694-0089 FAX: (239)694-0031 [www.mcscontrols.com](http://www.mcscontrols.com)

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.