



SOFTWARE RELEASE NOTES

MCS-MAGNUM Version 14.01N 09/19/2013

Updates from previous versions:

Bug Fixes:

***Change made to the EXV logic, this affects all software that supports EXVs.**

1. When the EXV's AO is placed in MANUAL status the EXV state is changed to holding and no adjustments will be made. When the AO was returned to AUTO, the EXV state remained in the holding state but adjustments are now allowed. From this point the AO will be modulated. Problem, if the EXV state is closed and you place the AO in MANUAL and then return the AO to AUTO, the EXV state remained in hold. Corrected this problem if the EXV state should be closed when the AO is returned to AUTO the EXV state will be closed.
2. Note, if the EXV is running and the AO is at 80% and it is being opened; you now place the AO in MANUAL at 10% (no adjustments are made), when you return the AO to AUTO; adjustments will be made beginning at an AO opening of 10% not 80%.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.