



SOFTWARE RELEASE NOTES

MCS-MAGNUM Version 14.02K 01/14/2014

Updates from previous versions:

New Features:

RTU:

1. The reverse control option for controlling the building static is active.
 - a. This will be used to close the O/S damper when the building static pressure is above its zone.
 - b. There are no changes to existing set points, only the selection of this option in the Building PSI Control section is required.
 - c. Setpoint #197 provides the target and zone for the building static, no change.
 - d. For example if the target is .05 and top of zone is .07 and bottom is .03
 - e. When the building static pressure is greater than .07 the O/A damper will be modulated closed to reduce the pressure. This will over ride all other controls (CO2, CFM, supply temperature).
 - f. When the building static pressure is within the zone but above the target the O/A damper will remain at its present opening.
 - g. When the building static pressure is below the target the O/A damper will be modulated based upon controls selected.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2014. Copying or distributing this document is prohibited unless expressly approved by MCS.