



SOFTWARE RELEASE NOTES

MCS-MAGNUM **Version 17.22E** **05/19/2016**

Updates from previous versions: 17.22D

New Features:

1. ACU: Added code to save_lockout_point_data for LOCKOUT & LAST SAFETY TRIP. Sent 17.22D2 hex to BWW for testing.
2. EXV Cond Level Control.

Bug Fixes:

1. ALL SW: R290 Pressure/Temperature Chart that we received from Zamil is for absolute Pressure not Gauge Pressure. Updated table sent 17.22D1 hex to Ahmad Omar Al-Najjar for test.
2. ACU: Passing erroneous lockout information data (120 sec history) to MCS-Connect. save_lockout_point_data was incorrect because circuit_index variable was never set. * Solution: Set circuit_index equal to cmp_index.
3. LWC: Updating FLA set points were being blocked; correct this.

Released Version 17.22E

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2016. Copying or distributing this document is prohibited unless expressly approved by MCS.