



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 8.05H

04/26/2011

Updates from previous versions:

New Features:

1. Added a test to check for a compressor in a ready state and an extra step of capacity is needed before unloading all running compressors.

Bug Fixes:

1. CENT ONLY: Modified conditions of the test to check for need to switch to VFD control. Now Variable Steps Wanted is compared every second with Calculated Max Variable Steps (used to be compared to a fixed Max Variable Steps setpoint).

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.