



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 8.05I

04/26/2011

Updates from previous versions:

New Features:

1. **CENT ONLY:** Added test to Vanes logic. If Vanes Wanted % and Actual Vanes % differ, then the Magnum will switch to Vanes Staging mode until they match.

Bug Fixes:

1. **CENT ONLY:** Corrected problem with vanes not opening when the unit state is "Unit Loaded" and demand limit is at 100%. The Vane Wanted % was set to 100%, but the actual position of the vane was not changing because the vanes only change when in the "Vane Loading" state, but the compressor state was getting set to "Loading Speed".
2. **CENT ONLY:** Changed LCD/Keypad display for 'Motor%' to display 'Motor FLA%' all the time (when centrifugal with VFD it used to display vane %)

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.