



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.00G

08/30/2011

Updates from previous versions:

New Features:

1. Added feature to turn on the alarm LED and Horn on the MCS-STAT (communicating thermostat) when the Magnum generates and alarm that turns on the Alarm Relay. The MCS-STAT can also be used to perform a lockout reset if the max number of lockouts per day has not already been exceeded.

Bug Fixes:

1. Changed pumpdown logic to keep the TurboCor compressor in the pumpdown state for 300 seconds each time the circuit is disabled (before it was only staying in pumpdown when the pumpdown switch was on).

HVAC ONLY:

2. Fixed problem with setpoint #106 "LEAD PUMP". The value in this setpoint was being used even when it was inactive, causing the wrong relay to engage when starting the lead pump/fan. Now when the setpoint is inactive it will default to a value of 0.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.