



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.00I

09/26/2011

Updates from previous versions:

Bug Fixes:

REFR SOFTWARE ONLY:

1. **Corrected the problem when either 'Electric' or 'Time Off' defrost options were selected and a circuit was in a defrost state and the Run/Stop switch was placed in stop. The number of circuit steps was not properly reduced. This enabled a circuit to run even when the step wanted or actual on were 0/0.**

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.