



SOFTWARE RELEASE NOTES

MCS-MAGNUM Version 9.00K 09/26/2011

Updates from previous versions:

Bug Fixes:

1. Corrected problem with Bacnet where the MCS-Magnum was sending a string and not a number when replying to a Multi-State Value point State Text property request.
 - a. Depending on MSV type(Alarm, Unit state or Circuit state) and SW type. Determine MULTISTATE_NUMBER_OF_STATES.
 - b. For Multi-State Value point State Text property request→ Property Array Index 0 reply with MULTISTATE_NUMBER_OF_STATES
 - c. For Multi-State Value point State Text property request→ Property Array Index BACNET_ARRAY_ALL reply with ERROR_CODE_NO_SPACE_FOR_OBJECT
 - d. For all other property array index numbers reply with a string.
 - e. Set MULTISTATE_NUMBER_OF_STATES to 1. We only have one possible state text per state value.

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.