



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.01D

11/29/2011

Updates from previous versions:

Bug Fixes:

HVAC SOFTWARE ONLY:

1. Changed the EXV Target Level calculation limiting. The limit was previously set to the high/low values of setpoint #9 "EXV TARGET". Now the upper limit is the value of setpoint #9 and the lower limit is the value of setpoint #217.

CENT SOFTWARE ONLY:

2. Expanded the vanes closed logic to accept a USER LOGIC type digital input as well as a digital input.
3. Changed purge logic to turn off the purge vent when the compressor goes off.

REFR SOFTWARE ONLY:

4. Corrected the pump down logic to ensure that both liquid lines 1 and 2 are turned off properly when entering the pumpdown state.
5. Removed the control power relay option from REFR software.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.