



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.11I

12/04/2012

Updates from previous versions:

Bug Fixes:

HVAC Only:

1. Modulating condenser logic has been updated.
2. Magnum LCD for Main Menu the F3 'LARGE' the bottom line on this screen has been modified to show:
 - a. MODE=HEAT TARG=110.0 (mode is heat & the heat target setpoint is displayed),
 - b. MODE=COOL TARG=45.0 (mode is cool & the cool target setpoint is displayed) or
 - c. MODE=ICE TARG=45.0 (mode is ice & the cool target setpoint is displayed)
3. Heat pump logic. The reversing valve when in heat mode is on. It will remain on unless the mode changes to cool, defrost cycle is initiated, or the system is off due to run/stop being off, no flow, schedule off, or high ambient off. It will be changed to off for the above reasons else it will remain on.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2012. Copying or distributing this document is prohibited unless expressly approved by MCS.