



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.11X

01/23/2013

Updates from previous versions:

New Features:

1. HVAC, added to the modulating condenser type: If heat pump and the mode is HEAT (not in defrost) all condenser relays will be turned on and the VFD set to 100% when the compressor is turned on. If the control pressure is above the control zone, the condenser will unload; if below the control zone the condenser will load else there will be no change. This needs to be tested with our chiller to determine if it meets our requirements. When satisfied it will be added to other software.

Bug Fixes:

1. All software correction to the single/multiple keypad entries. Original function added to 9.11-T software.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.