



SOFTWARE RELEASE NOTES

MCS-MAGNUM

Version 9.13D

04/26/2013

Updates from previous versions:

RTU Only:

Bug Fixes:

1. Will not let the mode change if steps in that mode are still on. For example the system is in cooling mode with 3 steps on and the mode is to be changed to fan only. Prior to this change the number of steps wanted on was set to 0 which resulted in a step being turned off with each pass of the algorithm. This change waits until all steps have been normally cycled off before the mode is changed.
2. AAON requested a change to the pre-heat function that was installed in the prior software release. The pre-heat function is to be disable (off state) when the unit is in either cooling or dehumidification mode. Updated documentation and it is attached.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.