



SOFTWARE RELEASE NOTES

MCS-MICROMAG

Version 14.00C

05/29/2013

Updates from previous versions:

New Features:

1. Added compressor number to compressor alarms.

Bug Fixes:

1. Changed name of RTU State "Off Demand" to "Off Satisfied"
2. Added emergency stop to alarm info popup index as false
3. Previously, alarm info was looking at the pointer, rather than the actual alarm number to determine whether to replace an alarm info. Resolution: Used the alarm number to determine whether to replace the alarm info.
4. Variable for max safety time was previously limited to values greater than 0, causing large values to become negative and eliminate safety down time. Resolution: Made variable for max safety time available to store negative values.
5. When in dehumidification and the suction temp was close to the freeze safety setpoint, cooling stages would not come on. Resolution: Removed suction temp comparison vs. freeze setpoint when in dehumidification.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.