



SOFTWARE RELEASE NOTES

MCS-MICROMAG

Version 15.00C

07/05/2013

Updates from previous versions:

Bug Fixes:

1. SIs were not displaying properly in main display on keypad when in Chiller mode (RTU names were popping up). Resolution: Created a separate function to point to the proper SI name. Names should appear properly now.
2. Cooling and Heating were not shutting off when unit was Unoccupied and unit schedule control is On/Off rather than offset control. Resolution: In the function, added checks for the occupation state and the unit schedule control in cooling and heating. Unit should shut off when it is unoccupied now.
3. The state timer was not incrementing when the unit state was in "OFF NET STOP" mode. This was due to the "next state" variable not being set to the proper value. Resolution: Changed the "next state" from off run/stop to off network run stop when the network stop AV point was off.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.