



SOFTWARE RELEASE NOTES

MCS-MICROMAG

Version 15.00D

07/10/2013

Updates from previous versions:

Bug Fixes:

1. Scrolling through the keypad could display DIFF PSI even if an oil pressure SI was unavailable. Resolution: Changed an AND to an OR, keypad will only display DIFF PSI if a compressor has a suction pressure SI AND an oil pressure SI.
2. Capacity control would not do a staging delay in cooling or heating if it was losing a stage. Resolution: Changed variable equals TRUE to variable is not equal to FALSE as the memory location can have different values depending on whether it is staging up or down. Staging Delay will now work after staging up and down.
3. Rotation would not rotate by days. Resolution: At midnight, if enough days have elapsed, rotated compressors by run time.
4. Evaporator and static target reset would stay in staging hold delay if it was in variable air volume control. Resolution: Set the internal "actual stages on" to 1, eliminating the staging hold delay problem.

Any questions regarding this release, contact:

support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.