



SOFTWARE RELEASE NOTES

MCS-MICROMAG

Version 15.00L

09/05/2013

Updates from previous versions:

New Features:

1. MicroMag now informs Thermostat whether the current config has an OAD.
2. MicroMag now transmits its occupied status to the Thermostat
3. Added reverse acting building static control
4. Alarms due to ignition now display "Ignition Fault" rather than "heater fault"

Bug Fixes:

1. BACnet Economizer state MSV was being enabled and disabled inappropriately. Resolution: Rather than add the Economizer State if the economizer is unused, the MicroMag now adds the Economizer State MSV if the economizer is NOT unused.
2. Morning Warm-up State previously did not shut the outside air damper. Resolution: Morning Warm-up State now closes the outside air damper.
3. Updated and added a few SI names
4. Certain SI names were showing up incorrectly because of an invalid memory reference. Resolution: Changed the name index in SIs, AOs, and ROs from signed to unsigned
5. Added definitions for future heating options

Any questions regarding this release, contact:
support@mcscontrols.com

Micro Control Systems, Inc. 5580 Enterprise Parkway Fort Myers, Florida 33905
(239)694-0089 FAX: (239)694-0031 www.mcscontrols.com

Information contained in this document has been prepared by Micro Control Systems, Inc. and is copyright © protected 2013. Copying or distributing this document is prohibited unless expressly approved by MCS.